

INSTALLATION INSTRUCTIONS

KIT MODEL: RXRX-LKG01 / MXRX-LKG01 LOUVER PANELS
FOR UNIT MODELS: : GEG & ACG 15-25T UNITS

▲ WARNING

▲ Recognize this symbol as an indication of Important Safety Information!

THESE INSTRUCTIONS ARE INTENDED AS AN AID TO QUALIFIED SERVICE PERSONNEL FOR PROPER INSTALLATION, ADJUSTMENT, AND OPERATION OF THIS KIT. READ THESE INSTRUCTIONS THOROUGHLY BEFORE ATTEMPTING INSTALLATION, ADJUSTMENT, OR OPERATION. FAILURE TO FOLLOW THESE INSTRUCTIONS CAN RESULT IN IMPROPER INSTALLATION, ADJUSTMENT, SERVICE, OR MAINTENANCE, AND POSSIBLY RESULT IN FIRE, ELECTRICAL SHOCK, PROPERTY DAMAGE, PERSONAL INJURY, OR DEATH.

PARTS LIST		
PART DESCRIPTION	Part #	Qty
Louver Panel	10-107707-27HT	3
Screws - Blunt Tip - 3/8"	63-42109-03	3
Screws - Sharp Tip - 5/8"	63-22338-11	21

A. REQUIRED TOOLS/SUPPLIES

- A. Box Cutter (to open packaging)
- B. Scratch Awl

- C. Nut Drivers:
 - 3/8"
 - 5/8"

▲ WARNING


BEFORE BEGINNING ANY MODIFICATION, BE SURE MAIN DISCONNECT SWITCH IS IN THE "OFF" POSOTION. FAILURE TO DO SO CAN CAUSE ELECTRICAL SHOCK RESULTING IN PROPERTY DAMAGE, PERSONAL INJURY, OR DEATH. TAG DISCONNECT WITH A SUITABLE WARNING LABEL.

B. INSTALLATION PROCEDURE FOR KIT:

1. Remove louver panels and mounting screws from package.
2. Place each lover panel onto the unit. Insert the blunt tip screws along the vertical sides first to retain panel in place; 1 screw per panel.

NOTE: DO NOT USE SHARP TIP SCREWS HERE; RISK OF COIL DAMAGE!

3. Insert the sharp tip scres to finish securing the panels; 7 screws per panel.



ST-A1343-01-00

